

Facility Summary in POWELL County in the City of DEER LODGE

Location: MAIN STREET SERVICE INC
520 MAIN ST
DEER LODGE, MT 59722 POWELL

Sys Fac ID: 39-04312

Last Inspected On: 4/28/2015

Operating Permit Renewal Date:

Contact: Angie McCullough, (406) 550-3064

Owners/Operators: Main Street Service Inc, Owner (406)-550-3064 5325 SIMMENTAL TRAIL
FLORENCE MT 59833
Estate of Tina B Schowengerdt, Operator (406)-550-3064 5325 SIMMENTAL TRAIL
FLORENCE MT 59833
Rocky Wozny, UST Class A Operator
Rocky Wozny, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	41	4/18/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3944			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		3/5/2009	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		7/29/2015	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
4,000		8/13/2013			
2	41	4/18/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3945			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		3/5/2009	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/29/2015	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
10,000		8/13/2013			
3	41	4/18/1974	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3844			Impressed Current	None	Yes
Temporarily Out of Use		3/5/2009	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/29/2015	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
10,000		8/13/2013			

Facility Summary in POWELL County in the City of DEER LODGE

Location: I 90 AUTO TRUCK PLAZA
1220 N MAIN ST
DEER LODGE, MT 59722 POWELL
Contact: Lawrence Fickler, (406) 846-3970

Sys Fac ID: 39-07856
Last Inspected On: 8/21/2013
Operating Permit Renewal Date: 12/26/2016

Owners/Operators: Fickler Oil Co Inc Deer Lodge, Owner (406)-846-3970 725 MAVERICK LN
DEER LODGE MT 59722-2347
Bonnie Cyr, UST Class A Operator
Bonnie Cyr, UST Class B Operator
Hazel Ehry, UST Class B Operator
Percy Moore, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	17	12/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3612			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					
11	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3613		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					
12	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4436		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					

Facility Summary in POWELL County in the City of DEER LODGE

Location: I 90 AUTO TRUCK PLAZA
1220 N MAIN ST
DEER LODGE, MT 59722 POWELL

Contact: Lawrence Fickler, (406) 846-3970

Sys Fac ID: 39-07856
Last Inspected On: 8/21/2013
Operating Permit Renewal Date: 12/26/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
13	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4437		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
14	12	6/26/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4847			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
15	12	6/26/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4848			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in POWELL County in the City of DEER LODGE

Location: TOWN PUMP INC DEER LODGE
203 N MAIN ST
DEER LODGE, MT 59722 POWELL

Sys Fac ID: 39-08694
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	38	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2589			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/24/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	38	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2590			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/24/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	38	4/14/1977	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2591			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		6/24/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	17	7/30/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2592			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/24/2014	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWELL County in the City of DEER LODGE

Location: TOWN PUMP INC DEER LODGE
203 N MAIN ST
DEER LODGE, MT 59722 POWELL

Sys Fac ID: 39-08694

Last Inspected On: 6/30/2015

Operating Permit Renewal Date: 10/14/2018

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	15	9/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4282			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		6/24/2014	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	15	9/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4283			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		6/24/2014	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in POWELL County in the City of DEER LODGE

Location: HAPPY ENDINGS 418
141 N INTERCHANGE
DEER LODGE, MT 59722 POWELL

Sys Fac ID: 39-10909

Last Inspected On: 7/16/2014

Operating Permit Renewal Date:

Contact: Todd Fickler, (406) 846-3970

Owners/Operators: T & TF Inc, Owner	(406)-846-3819	725 MAVERICK LANE DEER LODGE MT 59722
Fickler Oil Co Inc Deer Lodge, Operator	(406)-846-3970	725 MAVERICK LN DEER LODGE MT 59722-2347
Randy Livingston, UST Class A Operator		
Keith Dowling, UST Class B Operator		
Randy Livingston, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	26	4/13/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
767			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/18/2008	TLS-350/Gilbarco EMC , Veeder Root		
4	17	11/19/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
768			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/18/2008			
5	17	11/19/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
769			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/18/2008			

Facility Summary in POWELL County in the City of DEER LODGE

Location: BROKEN CIRCLE RANCH CO INC
3850 EASTSIDE RD
DEER LODGE, MT 59722 POWELL
Contact: Del Nicholson, (406) 846-9614

Sys Fac ID: 39-13744
Last Inspected On: 1/27/2015
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: Broken Circle Ranch Co Inc, Owner (406)-846-9318 3987 EASTSIDE RD
DEER LODGE MT 59722-9520
Jennifer Nicholson, UST Class A Operator
Jereme Nicholson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4624			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
2	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4625			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in POWELL County in the City of ELLISTON

Location: ELLISTON STORE
104 E FRONT ST
ELLISTON, MT 59728 POWELL
Contact: Bill Thomas, (406) 492-6391

Sys Fac ID: 39-05196
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 12/27/2017

Owners/Operators: William Thomas, Owner (406)-492-6391 PO BOX 15
ELLISTON MT 59728-0015

Bill Thomas, UST Class A Operator
Melissa Thomas, UST Class A Operator
William Thomas, UST Class A Operator
Melissa Thomas, UST Class B Operator
William Thomas, UST Class B Operator
Bill Thomas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	30	5/6/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3856		4/28/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		11/3/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	30	5/6/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3857		4/28/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		11/3/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWELL County in the City of GARRISON

Location: GARRISON MERCANTILE & POST OFFICE INC
INTERSTATE 90 & US HIGHWAY 12
GARRISON, MT 59731 POWELL

Sys Fac ID: 39-03405

Last Inspected On: 8/17/2015

Operating Permit Renewal Date:

Contact: Judith M Wood, (406) 846-9961

Owners/Operators: Garrison Mercantile & Post Office Inc, Owner (406)-846-3505 PO BOX 636
GARRISON MT 59731-0636

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	34	5/5/1981	Cathodically Protected Steel	Steel	
3934			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use				Safe Suction	Impressed Current
Gasoline		8/18/2015	Automatic Tank Gauging 0.1	Deferred	
5,000					
2	34	5/5/1981	Cathodically Protected Steel	Steel	
3935			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use				Safe Suction	Impressed Current
Gasoline		8/18/2015	Automatic Tank Gauging 0.1	Deferred	
5,000					

Facility Summary in POWELL County in the City of OVANDO

Location: BLACKFOOT COMMERCIAL CO LLC
406 PINE ST W
OVANDO, MT 59854 POWELL

Sys Fac ID: 39-02276

Last Inspected On: 10/28/2013

Operating Permit Renewal Date: 11/30/2016

Contact: Dennis Sharp, (406) 793-5555

Owners/Operators: Blackfoot Commercial Co, Owner (406)-793-5555 PO BOX 108
OVANDO MT 59854
Dennis Sharp, Operator (406)-793-5555 406 PINE STREET W
OVANDO MT 59854
Howard G Fly, UST Class A Operator
Howard G Fly, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	6/1/1996	Aboveground Tank	Fiberglass Reinforced Plastic	
3362	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
1,000		10/31/2013			
2	19	6/1/1996	Aboveground Tank	Fiberglass Reinforced Plastic	
3363	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
3,000		10/31/2013			
3	19	6/1/1996	Aboveground Tank	Fiberglass Reinforced Plastic	
3364	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
1,000		10/31/2013			